

## Publication No. 72-e35

WA-37-1020

TO: John Hodgson

DATE: October 26, 1972

FROM: Scott Jeane

SUBJECT: Efficiency Study of Waste Treatment Facilities at  
Stokely Van Camp, Zillah, Washington

OBJECTIVE: To determine the efficiency of the company's primary pre-treatment system and if the non-overflow lagoon system has an effect on the water quality of adjacent water courses.

The efficiency survey took place on September 13, 1972. Composite samples represent 6 hours of sampling at 1/2 hour intervals. The grab samples were taken in the early afternoon (see Figure 1). In addition to the plant samples, the adjacent slough was sampled above and below the non-overflow lagoons. See also the Yakima River Survey completed the preceding day. (DATE OF MEMO)

Parameter Analysis

The upstream and downstream slough grab samples were analyzed for COD, BOD, total suspended solids, and total suspended nonvolatile solids (see Table 1). The analysis showed no effect of the lagoons upon the slough. The clarifier influent and effluent were sampled by grab and composite methods. Both methods of sampling agree and show no major differences. Total coliform increased from 16,000 to 780,000 colonies/100 ml while in the clarifier. The COD demonstrated 81% reduction while BOD was 57%. The solids profile revealed 93% reduction in total suspended solids while settleable solids decreased 97.6%.

The clarifier influent sampling location was compared to a sample point taken immediately below the screens. These two grab samples show no differences except for the COD. The unusually low COD on the below screen sample may have been caused by partial blockage of the sample pipe preventing larger particles from being sampled.

General Observations

While the sampling was in progress a tour of the lagoons was taken. The two lagoons marked empty on Figure 2 had a fair amount of effluent being discharged to them. Because of the high rate of either or both evaporation and infiltration both lagoons were for the most part empty. At one place some seepage was noted (see Figure 2 and slide 1). The three stagnant sloughs located next to the back lagoons were black in color and unusually high in organic material. The septic condition of these sloughs is related to infiltration of process waste into them.

Slides of the lagoons and treatment facilities are included.

### Conclusions

The pretreatment plant is operating at an efficiency level greater than reported by designing firm. As long as the effluent is confined to the non-overflow lagoons, the Yakima River water quality will not be effected. An odor problem should not develop as long as the pretreatment plant is operating correctly. If the company wished to discharge to the river they would have to increase the BOD reduction from the observed 57% to the required 85%, while the total suspended solids would have to be reduced only 2% more. The high total coliform (780,000 colonies/ml) would make chlorination necessity.

The observed lagoon design did not match the design put forth in Item F by Stokely Van Camp. The seepage (see Figure 2 and Photograph 1) I observed was small but had turned the several small stagnant sloughs into blackish sulfidiferous sink holes. The stagnant sloughs should probably be filled and the weeping dike strengthened by the addition of more fill.

Personnel from the company were supposed to split samples with us but the person responsible for testing the samples was gone and no one else requested samples.


GSJ:bj

Attachments


Table 1. Stokely Van Camp at Zillah, Sample date 9/13/72.

Station	pH	COD	BOD	T. Coliform (Col./100ml)	Total Solids	TSS	TSNVS	Chlorides
Clarifier Effluent (Composite)	9.3	3500	1960	80000	3.0	555	117	160
Clarifier Effluent (Grab)		3350	2040			635	127	
Influent (Composite)	10.8	18300	4570	16000	125	7660	410	
Influent (Grab)		14900	2600			2915	385	
Influent below screen (Grab)		5500	2730			3795	315	
Slough - above lagoons (Grab)		11	2			26	21	
Slough - below lagoons (Grab)		15	2			20	15	

Figure 1. Stokely Van Camp, Inc. at Zillah  
 Sample Station Locations, 9/13/72.



+ NW corner SEC 36  
T-11N, R20E




Scale  
1" = 300'

Figure 2. Lagoon condition at Stokely Van Camp, Zillah, on September 13, 1972.

Stokely Mile Zillah

ITEM - F  
LOCATION OF WASTE WATER DISCHARGE FOR STOKELY VAN CAMP, INC.,  
ZILLAH, WASH.



# DEPARTMENT OF ECOLOGY

WATER QUALITY LABORATORY

COPIES TO:  
G.S. JEANE...

## DATA SUMMARY

LAB FILES

Source STOKELY-VAN CAMP

Collected By G.S. JEANE

Date Collected 9/13/72

Goal, Pro./Obj. 3.2-23

Log Number:	72-3452 -3453 -3454 -3455 -3456 -3457 -3458 -3459 -3460									STORET
Station:	UPSTR SLOUGH	DNSTR. SLOUGH	GRAB BELOW SCREEN	GRAB INF	GRAB CLAR.	COMP. CLAR.	COMP. INF	COMP CLAR	COMP INF	
pH						9.3	16.8			00403
Turbidity (JTU)										00070
Conductivity (umhos/cm)										00095
COD	11	15	5500	14900	3350	3500	18300			00340
BOD (5 day)	<2	<2	2730	2600	2040	1960	4570			00310
Total Coliform (Col./100ml)								780000	16000	31504
Fecal Coliform (Col./100ml)										31616
NO3-N (Filtered)										00620
NO2-N (Filtered)										00615
NH3-N (Unfiltered)										00610
T. Kjeldahl-N (Unfiltered)										00625
O-PO4-P (Filtered)										00671
Total Phos.-P (Unfiltered)										00665
Total Solids						3.0	125			00500
Total Non Vol. Solids										
Total Suspended Solids	26	20	3795	2915	635	555	7660			00530
Total Sus. Non Vol. Solids	21	15	315	385	127	117	410			
CHLORIDES	-	-				160				00940

Note: All results are in PPM unless otherwise specified. ND is "None Detected"  
Convert those marked with a \* to PPB (PPM X 10<sup>3</sup>) prior to entry into STORET

72-3452, 3453 - INSUFFICIENT  
SAMPLE LEFT FOR CHLORIDES.

Summary By Mary F. Walcott Date 9/25/72

# MEMORANDUM

Department of Ecology  
Yakima District Office  
504 N. Naches Avenue - Suite 10  
Yakima, WA 98901  
Phone No. - CH 8-0981  
Scan Phone No. - 372-1213

Information  
For Action  
Permit  
Other

Check


TO: ~~Don Pine, Dan Neal and~~  
Stokely Van-Camp - Zillah Files

DATE: June 26, 1972

FROM: John W. Hodgson

SUBJECT: ~~Treatment System Efficiency Survey and Water~~  
Quality Survey - Yakima River

**Objective:** To determine the efficiency of the company's primary pre-treatment system and the effect, if any, of the non-overflow lagoon system on the quality of adjacent surface water courses.

**Description:** Stokely Van-Camp discharges asparagus and potato processing waters through a primary treatment system to a non-overflow lagoon system which is located within the flood plain of the Yakima River. The primary treatment system consists of a circular clarifier, sludge draw off system and vacuum filter. This system was designed by Gary & Osborne in 1967 and was to provide 90% reduction in suspended solids and 30% reduction in C.O.D. . The non-overflow lagoon system consists of 6 cells and has a total surface area of approximately 14 acres. (See attached sketches of lagoon system and waste flow schematic.)

### Expected Results:

1. Efficiency of primary treatment facility by testing for:
  - (a) Flow - including cooling water.
  - (b) PH. - primary influent, primary effluent
  - (c) Temperature - including cooling water if discharged separate during survey
  - (d) Settleable solids - primary influent and effluent
  - (e) Suspended solids - primary in influent and effluent
  - (f) C.O.D. - primary influent and effluent
  - (g) B.O.D. - primary influent and effluent
2. Determine reliability of company's testing program by splitting samples b,d,e,f, and g with Mr. Dalton of Stokely Van-Camp. *2 grab samples*
3. Determine the effects, if any, of seepage from the non-overflow lagoon by sampling the adjacent surface water source above, along side of and below the lagoon for:
  - (a) B.O.D.
  - (b) C.O.D.
  - (c) Nitrates
  - (d) Phosphates
  - (e) Dissolved Oxygen
  - (f) PH.
  - (g) Conductivity
  - (h) Visual observations of water quality and bottom org/nisms.
  - (i) Hydrogen sulfide - each lagoon cell.

### Recommended Sampling Stations:

1. Establishing sampling stations should be co-ordinated with Mr. Tom Dalton (telephone #829-5121 Zillah) of Stokely Van-Camp. The tests specified in number 2 above are the same as those required of the industry and are performed

DALLAS ANDERSON

on a routine basis.

2. With regard to sampling the slough, a minimum of three (3) sampling stations should be used. One upstream or above the lagoons, one along side of and adjacent to the lagoons in the area of the influent line and one downstream or below the lagoons.

Time Schedule:


As the company processes potatoes from July 13 to November 28, the survey should be conducted during that period. I would assume the best time would be between August 1 and September 30, 1972, during the period of low stream flow and high waste water discharge volumes.

JWH:d1  
6-26-72

cc: D of E - Olympia - Ron Pine  
Spokane - Dan Neal  
Yakima

ITEM - F


LOCATION OF WASTE WATER DISCHARGE FOR STOKELY-VAN CAMP, INC.,  
ZILLAH, WASH.



SCALE 1" = 300'  
CRD

STOKELY VAN CAMP, INC. ZILLAH, WA.

EXHIBIT 1  
SCHEMATIC OF WASTE FLOW



MEMORANDUM

CHECK  
INFORMATION  
FOR ACTION  
PERMIT  
OTHER

TO John Arnquist, John Hodgson, Ron Devitt  
Ron Pine and Files.

FROM Darrel Anderson

SUBJECT Zillah STP

DATE October 10, 1973

State of  
Washington  
Department  
of Ecology



On September 13, 1973, I conducted an efficiency survey at the City of Zillah STP. Security at the plant is very good-general housekeeping is fair.

The new operator, Bob Cory, is a part time operator of the plant. He has had no schooling and does not understand the operation of a STP plant. The laboratory equipment at the plant is outdated and looks as if it had never been used.

The plant discharges into a slough from the Yakima River and the slough is quite turbid, but no odor or floating material is present.

The 5-day BOD reduction is 69%, COD is 60%. Total solids is 30% and T.S.V.S. is 16%. Fecal Coliform was no greater than 16,000/100ml.

DA:jmh

STP SURVEY REPORT FORM

(EFFICIENCY STUDY)

Activated

City Zillah Plant Type Sludge Population 1300 Design Unknown  
Served Capacity

Receiving Water Yakima River via Pond Engineer Dee Tufts

Date Sept. 13, 1973 Survey Period 0830 Survey Personnel D.L. Anderson

Comp. Sampling Frequency 1/2 hr. Weather Conditions Clear & hot.  
(last 48 hours)

Sampling Alequot 600 ml.

PLANT OPERATION

Total Flow ----- How Measured 3" parshall flume

Max. (Flow) 153,000 Time of Max. 0900 Min. 106,000 Time of Min. 1600

Pre Cl<sub>2</sub> ----- #/day Post Cl<sub>2</sub> 10 #/day

FIELD RESULTS

Influent

Effluent

Determinations	Influent				Effluent			
	Max.	Min.	Mean	Median	Max.	Min.	Mean	Median
Temp. °C	22.2	21.1	22.0	22.1	22.0	21.0	21.5	21.6
pH	8.5	7.6	7.4	7.7	7.6	7.2	7.5	7.4
Conductivity (umhos/cm)		Undetermined				Undetermined		
Settleable Solids	10.0	5.0	7.8	9.2		Trace		

LABORATORY RESULTS ON COMPOSITE IN PPM

Laboratory Number	Influent	Effluent	% Reduction
	73-3358	59	
5-Day BOD	219	69	69
COD	404	164	60
T.S.	891	629	30
T.N.V.S.	491	413	16
T.S.S.	230	73	69
N.V.S.S.	45	11	76
pH	8.0	7.9	
Conductivity	1150	1100	
Turbidity	72	33	

BACTERIOLOGICAL RESULTS

Na<sub>2</sub>S<sub>2</sub>O<sub>3</sub> added to sample Before sample

LAB #	SAMPLING TIME	COLONIES/100 MLS (MF)	Cl Residual	
			ppm	
73-60	1000	>16,000	1.0	1.5
61	1300	>14,000	.8	2.0
62	1530	>16,000	.8	1.0

Operator's Name Bob Cory Phone # 829-5151

Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

STATE OF WASHINGTON  
DEPARTMENT OF ECOLOGY

WATER QUALITY LABORATORY

ORIGINAL TO:  
. D. Anderson.  
COPIES TO:  
.....  
.....  
LAB FILES: .....

DATA SUMMARY

Source ZILLAH STP

Collected By D.A.

Date Collected 9-13-73

Goal, Pro./Obj. \_\_\_\_\_

Log Number:	23-3358	59	60	61	62						STORET
Station:	1MF	EFF	1000	1300	1530						
pH	8.0	7.9									00403
Turbidity (JTU)	72.	33.									00070
Conductivity (umhos/cm)@25°C	1150	1100									00095
COD	404	164									00340
BOD (5 day)	219	69									00310
Total Coliform (Col./100ml)	-	-	>80,000	>80,000	>80,000						31504
Fecal Coliform (Col./100ml)	-	-	>16,000	14,000	>16,000						31616
NO3-N (Filtered)											00620
NO2-N (Filtered)											00615
NH3-N (Unfiltered)											00610
T. Kjeldahl-N (Unfiltered)											00625
O-PO4-P (Filtered)											00671
Total Phos.-P (Unfiltered)											00665
Total Solids	891	629									00500
Total Non Vol. Solids	491	413									
Total Suspended Solids	230	73									00530
Total Sus. Non Vol. Solids	45	11									

Note: All results are in PPM unless otherwise specified. ND is "None Detected"  
Convert those marked with a \* to PPB (PPM X 10<sup>3</sup>) prior to entry into STORET

Summary By Stephen D. Roll Date 10-3-73

Calcutt

U.S. DEPARTMENT OF THE INTERIOR  
FEDERAL WATER POLLUTION CONTROL ADMINISTRATION  
SEWAGE TREATMENT PLANT OPERATION AND MAINTENANCE  
PRACTICES QUESTIONNAIRE

FORM APPROVED  
BUDGET BUREAU NO. 42-11527

CHECK ONE <input type="checkbox"/> 1ST AUDIT <input checked="" type="checkbox"/> RE-AUDIT	DATE OF AUDIT 9-13-73	PLANT DESCRIPTION CODE (For Official Use Only)
--	--------------------------	--

A. GENERAL INFORMATION

1. PROJECT (State, Number)	SCOPE OF PROJECT (new plant, additions, etc.)
2. PLANT LOCATION (City, county) 211141 - YAKIMA	IDENTIFICATION OF AREAS SERVED City of Yakima

3. POPULATION

3A. PERCENTAGE OF AREA POPULATION SERVED (%) 100%	3B. PLANT DESIGN (population equivalent) 1150	3C. SERVED BY PLANT (domestic) 1300
--	--	--


4. TYPE OF COLLECTION SYSTEM

4A. <input checked="" type="checkbox"/> COMBINED <input type="checkbox"/> SEPARATE <input type="checkbox"/> BOTH	4B. ESTIMATED FLOW CONTRIBUTED BY SURFACE OR GROUND WATER (infiltration, mgd) unk
--	--

5. YEAR COMMUNITY BEGAN SEWAGE TREATMENT 1937 - Remodeled - 1955	6. YEAR PRESENT SYSTEM PLACED IN OPERATION		
	6A. SEWER 1937	6B. PLANT 1937	6C. ANCILLARY WORKS

7A. SIZE OF PLANT SITE (acres) 1 acre	7B. APPROXIMATE AREA LEFT FOR EXPANSION (acres) none
--	---

8A. IN THE SPACE PROVIDED BELOW FURNISH A SIMPLIFIED FLOW DIAGRAM OR A WRITTEN DESCRIPTION OF THE PLANT UNITS IN FLOW SEQUENCE. INCLUDE THE METHOD OF ULTIMATE SLUDGE DISPOSAL. SHOW APPROXIMATE SURFACE AREA OF STABILIZATION PONDS AND NUMBER OF CELLS. INDICATE WHETHER FLOW TO AND FROM PLANT IS BY PUMPING OR GRAVITY.



8B. NOTE ANY SIGNIFICANT OR UNIQUE PROCESSING CONDITIONS.

9. RECEIVING STREAM

9A. NAME OF STREAM YAKIMA RIVER
------------------------------------

9B. STREAM FLOW IS <input checked="" type="checkbox"/> PERENNIAL <input type="checkbox"/> INTERMITTENT <input checked="" type="checkbox"/> NATURAL <input checked="" type="checkbox"/> REGULATED	<input checked="" type="checkbox"/> INTERSTATE <input type="checkbox"/> INTRASTATE
	<input type="checkbox"/> COASTAL

B. CURRENT PERFORMANCE AND PLANT LOADING INFORMATION

1A. ANNUAL AVERAGE DAILY FLOW RATE (mgd) unk.	1B. PEAK FLOW RATE (mgd) DRY WEATHER: unk. WET WEATHER: unk.	1C. MINIMUM FLOW RATE (mgd) unk.
--	--	-------------------------------------

2. AVERAGE BOD OF RAW SEWAGE (5 DAY 20°C) (ppm) unk.	3. AVERAGE SETTLEABLE SOLIDS OF RAW SEWAGE (mg/l) unk.
---	---

4. AVERAGE SUSPENDED SOLIDS OF RAW SEWAGE (mg/l) unk.	5. AVERAGE COLIFORM DENSITY OF RAW SEWAGE (mpn/100 ml) unk.
--	--

5. ANNUAL AVERAGE PLANT PERFORMANCE

6A. BOD (%) unk.	6B. SETTLEABLE SOLIDS (%) unk.	6C. SUSPENDED SOLIDS (%) unk.	6D. COLIFORM DENSITY (%) unk.
---------------------	-----------------------------------	----------------------------------	----------------------------------

7A. DOES PLANT HAVE STANDBY POWER GENERATOR FOR MAJOR PUMPING FACILITIES?  YES  NO

7B. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES?  YES  NO

8. ARE CHLORINATION FACILITIES PROVIDED?  YES  NO  
 IF YES, ANSWER 8A THRU G

IF YES, IS CHLORINATION CONTINUOUS?  YES  NO  
 IF NO, EXPLAIN REASON FOR INTERMITTENT CHLORINATION

8A. PURPOSE OF CHLORINATION  
*Disinfection*

8B. TYPE OF CHLORINATOR  
*WALLACE & TIERNAN*

8C. POINT OF APPLICATION OF CHLORINE  
*AFTER SECONDARY clarifiers*

8D. CAN BYPASSED SEWAGE BE CHLORINATED?  YES  NO

8E. AVERAGE FEED RATE OF CHLORINE (lb/day)  
*10*

8F. CHLORINE RESIDUAL IN EFFLUENT  
*1.0* PPM AT END OF *3* MINUTES

8G. MINIMUM SUPPLY OF CHLORINE STORED ON PREMISES (lb)  
*239*

9. ARE FACILITIES PROVIDED FOR COMPLETE BYPASS OF RAW SEWAGE?  
 YES  NO IF YES, ANSWER A THRU G BELOW, ANSWER H IN EITHER CASE.

9A. FREQUENCY (times monthly)  
*none*

9B. AVERAGE DURATION (hours)  
*none*

9C. REASON FOR BYPASSING  
*none*

9D. ESTIMATED FLOW RATE DURING BYPASS IS  
 WITHIN HYDRAULIC CAPACITY OF PLANT  
 BEYOND HYDRAULIC CAPACITY OF PLANT BY *unk.*

9E. DOES SEWAGE OVERFLOW IN DRY WEATHER?  
 YES  NO

9F. TYPE OF DIVERSION STRUCTURE  
*unk.*

9G. AGENCIES NOTIFIED OF BYPASS ACTION

9H. DO OPERATORS HAVE OPTION TO BYPASS INDIVIDUAL PLANT UNITS? (If no, has this caused any operational problems?)  
 YES  NO *unk.*

10A. ARE BACK FLOW DEVICES PROVIDED AT ALL CONNECTIONS TO CITY WATER SUPPLY? (If no, explain)  
 YES  NO

10B. CHECK TYPE OF BACK FLOW PREVENTION DEVICE  
 DOUBLE CHECK VALVE  PRESSURE OPERATED  PHYSICAL DISCONNECT  OTHER (specify)

11. USES OF TREATMENT PLANT EFFLUENT  
*none*

12. USES OF RECEIVING STREAM WITHIN 10 MILES OF OUTFALL  
*Fishing*

13. HAVE THERE BEEN ANY ODOR COMPLAINTS BEYOND THE PLANT PROPERTY? (If yes, explain)  
 YES  NO  
*sludge build-up - has been corrected*

14. OBSERVED APPEARANCE AND CONDITION OF EFFLUENT, RECEIVING STREAM, OR DRAINAGE WAY

15. STABILIZATION PONDS

A. WEEDS CUT AND VEGETATIVE GROWTH IN PONDS ELIMINATED?

YES  NO

B. BANKS AND DIKES MAINTAINED (erosion etc.)?

YES  NO

C. FENCING AND BARRICADING "POLLUTED WATER" SIGNS PRESENT AND IN GOOD REPAIR?

YES  NO

D. FREQUENCY OF INSPECTION BY OPERATOR

E. WATER DEPTH (feet)

\_\_\_\_\_ HIGH \_\_\_\_\_ LOW \_\_\_\_\_ MEDIUM

F. ADEQUATE CONTROL OF DEPTH?

YES  NO

G. SEEPAGE REPORTED?

YES  NO

H. ANY REPORTS OF GROUND WATER CONTAMINATION FROM POND (If yes, give details)?

YES  NO

I. MOSQUITO BREEDING PROBLEM?

YES  NO

IF YES, NAME OF SPECIES IF KNOWN

J. CAN SURFACE RUN-OFF ENTER POND?

YES  NO

C. SUPERVISORY SERVICES

1. IS A CONSULTING ENGINEER RETAINED OR AVAILABLE FOR CONSULTATION ON OPERATING AND MAINTENANCE PROBLEMS?

YES  NO IF YES IS IT ON:  CONTINUING BASIS OR  UPON REQUEST BASIS

IF CONTINUING BASIS, WHAT IS THE FREQUENCY OF VISITS: *P1*

2. DO OPERATORS AND OTHER PERSONNEL ROUTINELY ATTEND SHORT COURSES, SCHOOLS OR OTHER TRAINING ACTIVITIES?

YES  NO

IF YES, CITE COURSE SPONSOR AND DATE OF LAST COURSE ATTENDED

*Col. 11-20-80 last course*

IF NO, DO YOU KNOW OF ANY COURSES AVAILABLE TO SERVE THIS AREA?

3A. ARE ALL EQUIPMENT AND PARTS OF THE PRESENT PLANT STILL IN OPERATION?

YES  NO (If no, explain)

B. ARE PROCESSING UNITS OPERATING AT DESIGN EFFICIENCY?

YES  NO (If no, explain)

4. HAVE THERE BEEN ANY DIFFICULTIES WITH THE SEWAGE TREATMENT PLANT?

A. STRUCTURAL  YES  NO (If yes explain)

B. MECHANICAL  YES  NO (If yes, explain)

C. OPERATIONAL  YES  NO (If yes, explain)

*no operator's manual*

D. BASED ON OPERATING EXPERIENCE TO DATE WHAT IF ANY CHANGES WOULD YOU RECOMMEND TO IMPROVE OPERATION OF THE PLANT?

5. ARE OPERATING RECORDS MAINTAINED? (If maintained, check general items included) <input type="checkbox"/> YES <input type="checkbox"/> NO						REPORTED? <input type="checkbox"/> YES <input type="checkbox"/> NO					
						TO WHOM?					
FREQUENCY	WEATHER	FLOW	SLUDGE HANDLED	CHEMICALS USED	DIGESTER	GRIT HANDLED	ELEC. USED	COST DATA	AIR USED	MAINTENANCE	OTHER
DAILY											
WEEKLY											
MONTHLY											
ANNUALLY											

6. ARE LABORATORY RECORDS MAINTAINED? (check appropriate box)  
 NOT AT ALL  DAILY  WEEKLY  MONTHLY  ANNUALLY

IF MAINTAINED CHECK FORM OF RECORD BELOW:

LOG BOOK  TABULAR SHEET  SEPARATE BY OPERATION  CONTROL CHARTS  GRAPHS

WHAT PLANT AND/OR LABORATORY EQUIPMENT, GAGES AND METERS ARE CALIBRATED PERIODICALLY?

7. IS LABORATORY TESTING ADEQUATE FOR THE CONTROL REQUIRED FOR THIS SIZE AND TYPE OF PLANT?

YES  NO (If no, explain)

B. INDUSTRIAL WASTES DISCHARGED TO MUNICIPAL SYSTEM:	A. NUMBER AND TYPES OF INDUSTRIES DISCHARGING TO SYSTEMS
B. POPULATION EQUIVALENT (BOD) OF INDUSTRIAL WASTES (pc)	C. POPULATION EQUIVALENT (SS) OF INDUSTRIAL WASTES (pc)
D. VOLUME OF INDUSTRIAL WASTES (mgd)	E. COMPOSITION AND CHARACTERISTICS OF INDUSTRIAL WASTES
F. MAIN DIFFICULTY EXPERIENCED WITH INDUSTRIAL WASTE (explain)	

8. HAVE INDUSTRIAL EFFLUENT PROBLEMS BEEN SOLVED?  YES  NO (If yes, how?)

9A. METHOD OR METHODS USED TO ASSESS INDUSTRIAL WASTE TREATMENT COST (check appropriate box)

NO CHARGE BY CITY  PROPERTY TAX  WATER USE ASSESSMENT  CHARGE BASED ON FLOW  
 CHARGED BASED ON BOD  CHARGE BASED ON SS  OTHER METHODS (describe)

COMMENT ON HOW CHARGE IS COLLECTED (fixed charge, sliding scale, etc.)

9B. IS INDUSTRIAL WASTE ORDINANCE IN EFFECT AND ENFORCED?  YES  NO

10. WHO PROVIDED INITIAL INSTRUCTION IN THE OPERATION OF THE PLANT?  
*unk*

11. IS A MANUAL OF PRACTICE OR INSTRUCTIONS AVAILABLE?  YES  NO *too old* IF YES, WHO WROTE AND PROVIDED IT?

12. ESTIMATE OF MAN-HOURS PER WEEK DEVOTED TO LABORATORY WORK AND MAINTENANCE OF RECORDS AND REPORTS

D. PLANT PERSONNEL (Annual Average Staff for Most Recent Year Reported in Section "F")

JOB CATEGORY	NUMBER	TOTAL MAN-HOURS PER WEEK	TOTAL NUMBER CERTIFIED OR LICENSED	RANGE IN YEARS EMPLOYED AT PRESENT PLANT	RANGE IN YEARS OF EXPERIENCE IN TREATMENT
1. SUPERINTENDENT					
2. OPERATORS		<i>none</i>			
3. LABORATORY TECHNICIANS					
4. LABORERS					
5. PART-TIME LABORERS					
6. TOTAL					

E. LABORATORY CONTROL

Enter test codes opposite appropriate items. If any of the below tests are used to monitor industrial wastes place an "X" in addition to the test code.

CODES

1 - 7 or more per week      3 - 1, 2, or 3 per week      5 - 2 or 3 per month      7 - Quarterly      9 - Annually  
 2 - 4, 5 or 6 per week      4 - as required      6 - 1 per month      8 - Semi-Annually

ITEM	RAW	PRIMARY EFFLUENT	MIXED LIQUOR	FINAL	SLUDGE			RECEIVING STREAM
					RAW	SUPER-NATANT	DIGESTOR	
1. BOD								
2. SUSPENDED SOLIDS								
3. SETTLEABLE SOLIDS								
4. SUSPENDED VOLATILE								
5. DISSOLVED OXYGEN								
6. TOTAL SOLIDS								
7. VOLATILE SOLIDS								
8. pH								
9. TEMPERATURE								
10. COLIFORM DENSITY								
11. RESIDUAL CHLORINE								
12. VOLATILE ACIDS								
13. M. B. STABILITY								
14. ALKALINITY								
15.								
16.								
17.								
18.								
19.								

F. OPERATION AND MAINTENANCE COST FOR PLANT

YEAR OF OPERATION	SALARIES/WAGES	ELECTRICITY	CHEMICALS	MAINTENANCE	OTHER ITEMS	TOTAL
MOST CURRENT YEAR 19						
PRIOR YEAR 19						
PRIOR YEAR 19						
PRIOR YEAR 19						

EVALUATION PERFORMED BY	TITLE	ORGANIZATION
DARREL ANDERSON	ENVIRA TECH II	DOE

INFORMATION FURNISHED BY	TITLE	ORGANIZATION	DATE
BOB CORY	PLANT OPERATOR	city of ZILLAH	9-13-73

1. ADDITIONAL REMARKS (If remarks refer to a particular item, identify by number)

2. GENERAL COMMENTS ON HOUSEKEEPING AND MAINTENANCE

3. REQUIREMENTS OF HIGHER AUTHORITY

3A. DOES THE PLANT PROVIDE THE DEGREE OF TREATMENT PRESENTLY REQUIRED BY THE STATE? (If no, explain)

YES  NO

3B. ARE THERE ANY PENDING ACTIONS (enforcement conferences, change in water quality standards, etc.) THAT WOULD REQUIRE UPGRADING OF TREATMENT BY THIS PLANT?

YES  NO (If yes, explain)

3C. NUMBER OF STATE INSPECTIONS OF PRESENT PLANT TO DATE.

4. IS ANY FOLLOW-THRU ACTION REQUIRED TO (1) CORRECT DEFICIENCIES IN THE PLANT OR ITS OPERATION OR (2) RESOLVE INDUSTRIAL WASTE PROBLEMS? (If yes, describe required corrective action)  YES  NO